

PO Box 1751
Adelaide SA 5001

250 Victoria Square/
Tarmatanyangga
Adelaide SA 5000

Tel : 1300 653 366
Fax : 1300 883 171

Internet : www.awqc.com.au
Email : awqc@sawater.com.au



FINAL REPORT

Report ID : 160091

Report Information

Submitting Organisation : 00121665 : Hanma Investments Pty Ltd
Account : 142611 : Hanma Investments Pty Ltd
AWQC Reference : 142611-2015-CSR-1 : Prod Test: Maxseal Flex
Project Reference : PT-2602
Product Designation : Maxseal Flex
Composition of Product : Component A - Aqueous Emulsion of Acrylic Polymer & Compound B - Waterproofing Cement (see attachments).
Product Manufacturer : DRIZORO, S.A., SPAIN.
Use of Product : In-Line/Waterproof Coating.
Sample Selection: As provided by the submitting organisation.
Testing Requested : **AS/NZS 4020:2005 TESTING OF PRODUCTS FOR USE IN CONTACT WITH DRINKING WATER**
Product Type : Composite
Samples : Samples were prepared and controlled as described in Appendix A of AS/NZS 4020:2005
Extracts : Extracts were prepared as described in Appendix C, F, G, H.
Project Completion Date : 05-Aug-2015
Project Comment : The results presented herein demonstrate compliance of Maxseal Flex to AS/NZS 4020:2005 when exposed at area to volume ratios up to 1000 mm²/L at 20°C ± 2°C.

PLEASE NOTE THAT THIS REPORT SHALL NOT BE REPRODUCED EXCEPT IN FULL

THE RESULTS STATED IN THIS REPORT RELATE TO THE SAMPLE OF THE PRODUCT SUBMITTED FOR TESTING. ANY CHANGES IN THE MATERIAL FORMULATION, PROCESS OF MANUFACTURE, THE METHOD OF APPLICATION, OR THE SURFACE AREA-TO-VOLUME RATIO IN THE END USE, COULD AFFECT THE SUITABILITY OF THE PRODUCT FOR USE IN CONTACT WITH DRINKING WATER

A handwritten signature in blue ink, appearing to read "Michael Glasson".

Michael Glasson
APPROVED SIGNATORY



Corporate Accreditation No.1115
Chemical and Biological Testing
Accredited for compliance with ISO/IEC 17025

WORLD RECOGNISED
ACCREDITATION

ABN 69336525019
SAW_PT_Final_New.RPT

A business unit of the South Australian Water Corporation

Page 1 of 6